

STONE CAP OR METAL COPING
REF. DETAIL R-13 FOR ALTERNATE
TERMINATIONS

SEALANT

FLEX-FLASH UN, FLEX-FLASH MB,
HYDROSEAL, OR OTHER APPROVED
FLASHING. REF. DETAIL R-12 FOR
ALTERNATE CORNER TRANSITIONS

BONDING ADHESIVE

HYDROFLEX 10
SEPARATION SHEET OR
OTHER APPROVED PROTECTION

APPROPRIATE SURFACING-
STONE OR PAVER BALLAST,
HYDROGUARD, GARDEN ROOF

MONOLITHIC MEMBRANE
6125-FR

HYDROSEAL RESIN
LIQUID FLASHING W/
HYDROSEAL FLEECE
(SEE NOTE 3)

FLEX-FLASH UN

4" MIN.

5/8" MIN. THICKNESS
FIRE RATED, TYPE "X"
GYPSUM BOARD
(i.e., SECUROCK)

MIN. 22 GAUGE STRUCTURAL
METAL DECK

FLEX-FLASH MB

FLEX-FLASH UN

3"

NOTES:

1. ADEQUATE STRUCTURAL SUPPORTS, NUMBER AND TYPE OF FASTENERS REQUIRED TO COMPLY WITH APPLICABLE CODES, SHOULD BE DETERMINED BY PROJECT A/E.
2. ADDITIONAL REINFORCING (MM6125 W/6" WIDE FLEX-FLASH F) IS REQUIRED OVER SUBSTRATE BOARD JOINTS FOR EXTENDED (10+ YEARS) WARRANTIES.
3. HYDROSEAL RESIN MUST EXTEND 4" MIN. ONTO THE APPROVED SUBSTRATE BEYOND THE MM6125 TERMINATION.



Monolithic
Membrane
6125-FR
ROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

TYPICAL PARAPET
GYPSUM BOARD/METAL DECK

SCALE: NONE
DATE: 06/01/19

R-11C