



NOTES:

1. PENETRATION MUST BE PROPERLY SECURED TO STRUCTURE TO PREVENT VERTICAL OR LATERAL MOVEMENT. EXPOSED DECK CLAMPS ARE NOT APPROPRIATE.
2. SURFACE PREP OF ALL PIPE MATERIALS SHOULD EXTEND $\frac{1}{8}$ " MAX. BEYOND FLASHING TERMINATION POINT. ALL STEEL TO BE POWER TOOL CLEAN PER SSPC-SP3*.
3. IN COVERED/BURIED CONDITIONS, THE FLASHING DETAIL SHOULD EXTENDED AS HIGH AS POSSIBLE. FLASHING MUST BE TERMINATED AT OVERBURDEN LEVEL AND NO LESS THAN 8" ABOVE SUBSTRATE.
4. ALL HYDROSEAL FLEECE, INCLUDING OVERLAPS, MUST BE SET IN AND COVERED OVER WITH HYDROSEAL RESIN.

*Society for Protective Coatings-Surface Preparation standard SP3 Power Tool Clean.



HydroSeal
Deck Membrane

AMERICAN HYDROTECH, INC.

TYPICAL ROUND PENETRATIONS
(PIPE, VENT, ETC.)

SCALE: NONE
DATE: 07/19

HS-7