



NOTES:

1. PENETRATION MUST BE PROPERLY SECURED TO STRUCTURE TO PREVENT VERTICAL OR LATERAL MOVEMENT. EXPOSED DECK CLAMPS ARE NOT APPROPRIATE.
2. ALL PIPE MATERIALS (PVC, COPPER, BRASS) REQUIRE ROUGHENING/SANDING, IN ADDITION TO WIPING W/SURFACE CONDITIONER FOR PROPER ADHESION OF MM6125. METAL PIPES MUST BE FREE OF ALL OIL AND RUST.
3. IN COVERED/BURIED CONDITIONS, THE FLASHING DETAIL SHOULD EXTENDED AS HIGH AS POSSIBLE. FLASHING MUST BE TERMINATED AT OVERBURDEN LEVEL AND NO LESS THAN 8" ABOVE SUBSTRATE.
4. REFER TO DETAIL HS1K-1 FOR THE PROPER APPLICATION OF HYDROSEAL 1K



Monolithic Membrane 6125-FR
WITH HYDROSEAL 1K

AMERICAN HYDROTECH, INC.

TYP. ROUND PENETRATIONS (PIPE, VENT, ETC.) WITH HYDROSEAL 1K

SCALE: NONE
DATE: 06/08/23

HS1K-2